

Service Items

Name	Description	Tier 1 Price	Unit Type	QTY	Taxable
Labor	See attached pages for details of work performed.	\$0.00	Hour	1	N
TOTAL*:	\$0.00				

* Not including taxes

Service Forms

Daily Form	Fill out every day, even on PMs, and projects
TECH NAME	Tom Timlin
DATE	12/5/22
TOOLS USED	hand tools
MATERIALS USED	none
DESCRIPTION OF WORK PERFORMED	Returned with the new burners. Pulled the burner out of the right boiler and found the new burners were not the same. Looked into it and the book onsite had the proper part number. Put the boiler back together and took combustion on both boilers. They are Both running good at this time.
HOURS	REGULAR:
	OVERTIME:

Boiler-2	Boiler inspection form
manufacturer	HTP
Unit location / Tag	B-2
model / Serial Number	Camera 12/05/2022 09:57
	AM.jpg



Electrical (connections/contactors)	All good
Burner Type (atmospheric/ induced)	Induced
Clean burner assembly (Sensors etc)	Cleaned
Flame Signal (as available)	9.3
Heat Exchanger Check	Pulled burner and cleaned heat exchanger
Main line pressure	
Manifold Pressure	Variable

Combustion Analysis	
Low water cut off check	Working properly
Relief Valves (JOG)	Jogged and sealed up properly
Expansion tank check	Good
Jog any valves associated with Boiler	All working properly
Condensate/neutralize r	Both boilers need a neutralizer added
Notes	Unit is running good at this time.

Boiler-1	Boiler inspection form
	manufacturer
	HTP
	Unit location / Tag
	B-1
	model / Serial Number
	Camera 12/05/2022 09:54
	AM.jpg



Electrical (connections/contactors)	All good
Burner Type (atmospheric/ induced)	Induced
Clean burner assembly (Sensors ect)	Cleaned
Flame Signal (as available)	9.5
Heat Exchanger Check	Pulled and cleaned the heat exchanger
Main line pressure	
Manifold Pressure	Variable
Combustion Analysis	
Low water cut off check	Working properly
Relief Valves (JOG)	Jogged and sealed up properly
Expansion tank check	Good
Jog any valves associated with Boiler	All working properly
Condensate/neutralize r	Recommend adding a neutralizer to both boilers
Notes	Boiler is running good at this time.




Attachments

Title

B-1 low fire


File Name

c4496fa5-28ea-4914-84b9-16e2362d030f.jpg




B-2 high fire

58d82fb4-a1ef-4e54-90be-98b43ee1a21b.jpg



B-1 high fire

7b417078-82c1-4d68-829c-7370fb8b32bd.jpg



B-2 low fire

451ee240-1585-438b-aac4-469d6b447350.jpg





Service Items

Name	Description	Tier 1 Price	Unit Type	QTY	Taxable
Labor	See attached pages for details of work performed.	\$0.00	Hour	1	N
TOTAL*:	\$0.00				
* Not including taxes					




Service Forms

Daily Form	Fill out every day, even on PMs, and projects
TECH NAME	Tom Timlin
DATE	3/8/23
TOOLS USED	hand tools
MATERIALS USED	1: Burner assembly (ordered)
DESCRIPTION OF WORK PERFORMED	Removed the burner assembly out of the boiler. Installed the new Burner in the boiler and made sure everything was sealed back up properly. Cycled the boiler and the unit came right on with no issues. Unit is running good at this time.
HOURS	REGULAR:
	OVERTIME:



Attachments

Title	File Name
20230308_093050 03/08/2023 02:36 PM	a9baa6bb-4fe6-4086-ab7f-ee8044f3c7bb.jpg



CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA063 Date of Visit: 12/5/22

Contractor Personnel on Site:

1. Tom Timlin 2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. Fall Maintenance on Boilers 1 & 2

Service Calls – Service Call Number and Description

1. CSS# _____
2. CSS# _____
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Thomas Timlin Date: 12/5/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, I certify that the above-named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed.
This is NOT a Certification that the Work was performed correctly – The COW simply verifies that that someone representing the Contractor was onsite and accomplished something

Print Name/Rank: Cynthia Croyle/ AFOS Date: 12/5/22

Signed: 

E-Mail: cynthia.a.croyle.ctr@army.mil

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA063 Date of Visit: 3/8/23

Contractor Personnel on Site:

1. Tom Timlin 2. Caleb McNanny

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____

Service Calls – Service Call Number and Description

1. CSS# 90708. Installed a new burner assembly in the boiler.
2. CSS# 90715. Installed a new burner assembly in the boiler.
3. CSS# _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Thomas Timlin Date: 3/8/23

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, I certify that the above-named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed.
This is NOT a Certification that the Work was performed correctly – The COW simply verifies that that someone representing the Contractor was onsite and accomplished something

Print Name/Rank: Cynthia Croyle/ AFOS Date: 3/8/23

Signed: 

E-Mail: cynthia.a.croyle.ctr@army.mil