

/

CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV002/015 Date of Visit: Sept. 16 2024

Contractor Personnel on Site:

1. Mike ~~Graley~~ 2. Adam Kimble

Work Performed: Graley

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. \_\_\_\_\_

**Service Calls** – Service Call Number and Description

1. CSS# \_\_\_\_\_
2. CSS# \_\_\_\_\_
3. CSS# \_\_\_\_\_

---

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Adam Kimble Date: Sept. 16 2024

Signed: Adam Kimble

To be signed by Facility Manager:

By signing the Certification of Work, I certify that the above-named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed. This is NOT a Certification that the Work was performed correctly – The COW simply verifies that someone representing the Contractor was onsite and accomplished something

Print Name/Rank: SFC Michael Warren Date: 16 SEP 24

Signed: Michael J. Warren

E-Mail: michael.j.warren.mil@army.mil

**Subject:** WV002 WO15415 CSS91856 The OMS shop has a BFP that needs replaced but can't be because it needs a new ball valve in order to shut off the water in order to change the BFP.

Hello,

You have a new URGENT work order request:

WV002 WO15415 CSS91856 The OMS shop has a BFP that needs replaced but can't be because it needs a new ball valve in order to shut off the water in order to change the BFP. This ticket is to replace the ball valve.

Work Order	Description	Site	Location / Fac. ID	CLIN #	Reported Date	Stat
15415	The OMS shop has a BFP that needs replaced but can't be because it needs a new ball valve in order to shut off the water in order to change the BFP. This ticket is to replace the ball valve.	99REG4	WV002-01	1002-BR	4/3/24 8:10 AM	INP

The address to this site is:

201 Industrial Park Road  
Beaver, WV 25813-9307

Here's the **CSS#91856, URGENT (7 DAYS to respond) service call work order#15415** for your action. Reminder to contact Reginald Cook if the service call once you reach the \$190 amount so he can contact the COR for approval to repair. Don't forget to have your tech complete the service call certification of work form (COW) and to provide before and after pictures. Pics must be provided with the COW form.

**NOTE: This is only approval for your tech to work on this scope of work. If site personnel requests other work to be completed outside of stated work - please ask them to put a service call request in with the AFOS or RFOS and then we can get their concerns addressed.**

Kindly reply so I will know you are in receipt of this email.

Best,

Angelica Northington

Work Orders Service Desk / 99th - Region 4A/4C

5285 Shawnee Road, Suite 510

Alexandria, VA 22312

703-738-5302

[angelica.northington@cmimgmt.com](mailto:angelica.northington@cmimgmt.com)

This message (including any attachments) contains confidential or privileged information intended for a specific individual and purpose, and is protected by law. If you are not the intended recipient, please notify the sender at (703) 738-5300. Any disclosure, copying, or distribution of this message, or the taking of any action based on it, is strictly prohibited.