

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 12/12/23

Contractor Personnel on Site:

1. <u>Postler and Jaeckle</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 95061 WO# 14066

Description of Repairs

Checked out all boilers and found all units operating at this time. All safety's operational. Normal maintenance items should be addressed to keep everything in working order as listed below.

- flame sensor replacement
- flush out condensate neutralization pans (no matl needed)
- remove mesh burners and flush / inspect HX's

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 12/20/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 20 Dec 2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil