

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 12/12/2023

Contractor Personnel on Site:

1. <u>Postler & Jaeckle</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 95064 WO# 14067

Description of Repairs

Ops check 2 boilers in ASMA bldg. Found both units water flow switches not opening circuit when tested. Need to shutdown drain and replace both switches. Need to remove burners and flush / check HXs.

All other functions test ok. The following items could be replaced to prevent future breakdowns as well but do test ok.

Flame sensors, spark electrodes and condensate drain neutralizer kits.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 12/19/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 19 Dec 2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil