

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY030 Date of Visit: 12/11/23

Contractor Personnel on Site:

1. <u>Postler and Jaeckle</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 95172 WO# 14069

Description of Repairs

Found power and gas supply to unit, opened fuel supply and turned on power to disconnect switch.
Found unit to cycle and ignite one time before dropping out and not continuing to reignite.
Found pressure switch port flooded with water after condensation was produced from first cycle.
Unit has a work drive sheave, broken belt, plugged filters, condensate pump that is not operational and needs to have maintenance performed including clearing drains.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 12/20/23

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 20 Dec 2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil