

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 12/11/23

Contractor Personnel on Site:

- | | |
|-------------------------------|----------|
| 1. <u>Postler and Jaeckle</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 95248 WO# 14095

Description of Repairs

Worked with John and Dave the site reps to determine that the details on this work order are actually for the Penn Yann location. In saying that John put a work order in to have the CHW pump seal replaced that was leaking during seasonal operation. Right now it is off and drained but there are signs of seal failure on the equipment

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 12/20/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 20 Dec 2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil