

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV046 Date of Visit: 10/16/2024

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 98191 WO# 16153

### Description of Repairs

Replaced seal on hot water pump on the glycol loop in the MBA.

---

---

---

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: 10/16/2024

Signed: Richard A. Barker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Thomas Mcburney Date: 10/31/24

Signed: T

E-Mail: \_\_\_\_\_