

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: GALAX VA Date of Visit: 3-26-25

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Keith Pearson</u> | 4. _____ |
| 2. <u>Wyatt Rose</u> | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 2966446 WO# 2614

Description of Repairs

Found oms Gate operator and Gate Completely inoperable
Something Hit it. New Gate & operator will be needed.
operator is 110VAC. Gate opening 20', Gate is
37' overall Height is 7' plus barb arms

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Keith Pearson Date: 3-26-25

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jordan Waugh GS-9 Date: 3/26/25

Signed: 

E-Mail: Jordan.t.waugh.civ@army.mil