

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA 035 Date of Visit: 4/17/19

Contractor Personnel on Site:

1. Jarod Hack 4. _____
2. _____ 5. _____
3. _____ 6. _____

Service Call Number

CSS# 17575 WO# 7571


Description of Repairs

Extended pvc exhaust pipe of both
boilers above roof for better exhaust.
Installed and sealed powers overtop
of uncased air locators on man doors

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Jared Hack Date: 4/17/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: ATMOPCn.12 A.R. Date: 04/17/2019

Signed: 

E-Mail: _____



