

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 5/24/23

Contractor Personnel on Site:

1. <u>Simplex</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

  CSS# 90900 WO# 11493

### Description of Repairs

Labor and material to a.) JCI will troubleshoot the Simplex 4100ES located in the rear building of the US Army. b.) Card 2, ID Net Card (250 Points) card missing/failed c.) Card 12, I/O Card missing/failed d.) card 4, True Alert Power Supply positive earth ground e.) JCI will install a new Simplex 4100ES SPS Power Supply f.) JCI will install a new Simplex I/O Graphic Board, please note – it was determined that a addressable nac converter that was also damaged in the strike a CSS ticket will be needed for further repairs.

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 5/31/23

Signed: Karlee Demain

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata Date: 05/31/2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil