

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA1660 - AMSA Date of Visit: 10-24-18

Contractor Personnel on Site:

1. MATT MEYERS
2. _____
3. _____
4. _____
5. _____
6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____

Inspection, Testing, and Certification

1. _____
2. _____
3. _____
4. _____

Other Recurring Services

1. _____
2. _____
3. _____
4. _____

Service Calls – Service Call Number and Description

1. 100 17427 Hot water tank pilot wont stay lit.
2. _____
3. _____

ATTACHMENT J-0200000-05
FORMS

Over and Above Repair Work – Order Number and Description of Work Completed

installed parts, approved by Joe and tested
water heater a few times. Stayed lit.
Also replaced thermo coupling.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: MATT MEYERS Date: 10-24-18

Signed: _____

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Shawn McKay Date: 10-24-18

Signed: _____

E-Mail: _____