

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA 079-01 Date of Visit: 10-16-18

Contractor Personnel on Site: Sentry

1. Mark Tomasic
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

Work Performed: Wrote 5994, 5995

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. Inspection of 2 Boilers ASSET # 6532-Boiler / 6533-Boiler
2. winter Change over For chiller ASSET # 3212-Chiller
3. \_\_\_\_\_
4. \_\_\_\_\_

**Inspection, Testing, and Certification**

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

**Other Recurring Services**

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

**Service Calls** – Service Call Number and Description

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_



**Over and Above Repair Work – Order Number and Description of Work Completed**

Performed Inspections of & cleaned 2 Boilers  
Performed winter change over on chiller, turned off  
chilled water pump, turned off valves to chiller, transfer  
30°F glycol to 55 gal drum about 20 gal removed from  
chiller & lines disabled chiller.  
on Top Boiler found around Flame sensor on burner cover  
plate is corroded, put some silicone around, Flame sensor, wire  
& ignitor Needs changed worn

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Mark Tomasic Date: 10-16-18  
Signed: Mark

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Josh Sutton Date: 16 Oct 18  
Signed: J. Sutton  
E-Mail: joshua.e.sutton2.civ@mail.mil

