

CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: 1A096-01

Date of Visit: 10-17-18

Contractor Personnel on Site: Sentry

1. Mark Tomasic
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

Work Performed: Wott 6004, 6005, 6278

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. Inspections of Boilers ASSET# 6645-Boiler-1
2. \_\_\_\_\_
3. \_\_\_\_\_
4. 6647-Boiler-2  
6621-Boiler  
winter change over

**Inspection, Testing, and Certification**

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

**Other Recurring Services**

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

**Service Calls** – Service Call Number and Description

1. Ductless mini split in Oms not cooling ASSET# 15103
2. \_\_\_\_\_
3. \_\_\_\_\_

**Over and Above Repair Work – Order Number and Description of Work Completed**

checked & cleaned Boiler #1 ASSET# 6645-Boiler-1  
Found low water cut out is leaking a little water  
1/2" gas vent line is corroded  
performed winter change over

---

Found other 2 Boilers shut down. Traced  
Keep OFF Leaks Asset 6647 & 6521

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Mark Tomasic Date: 10-17-18  
Signed: Mark

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Mitchell Morrison SSG Date: 10-17-18  
Signed: C  
E-Mail: Mitchell.w.morrison.mil@mail.mil