

CERTIFICATION OF WORK
SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA013 Date of Visit: 2/14/19

Contractor Personnel on Site:

1. Dale Dohanich 4. _____
2. _____ 5. _____
3. _____ 6. _____

Service Call Number

CSS# 17109 WO# W07458

Description of Repairs

Removed & Replaced Mechanical Seal. Rebuilt Pump
Assembly & Sealed. Ran System - All ops OK
at this time

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Dale Dohanich Date: 2/14/19

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Richard T. Sayre Date: 14/Feb/19

Signed: [Signature]

E-Mail: _____



IMPORTANT
 Ceramic insert supplied with this re-
 seal assembly is highly polished
 Always install the polished side
 of the seal so that it mates with

P81236

Bell & Gossett

SEAL KIT 186499LF

a xylem brand

Genuine Bell & Gossett Replacement Parts

"A" SEALS

SEAL RING
ASSEMBLY

INSERT
BASKET

SEAL RING
ASSEMBLY

MORTON GROVE, IL USA