

Over and Above Repair Work – Order Number and Description of Work Completed

CLEARFIELD GATE HINGE & LATCH REPAIR

WO # 7171

CSS # 16948

REPLACED HINGES ON BULKHEAD SIDE OF GATE
WELDED BOLT ON LATCH TO PREVENT LOOSENING
WELDED ALL NUTS ON HINGES TO PREVENT LOOSENING

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: CUSTOM CONSTRUCTION/Chris Myrtle Date: 2-14-19

Signed: Chris Myrtle

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Timothy S Peters Date: 15 February 2019

PETERS.TIMOTHY.SCOTT.10372

Digitally signed by

PETERS.TIMOTHY.SCOTT.1037293977

Date: 2019.02.15 08:24:20-05'00'

Signed: 93977

E-Mail: timothy.s.peters3.ctr@mail.mil











