

CERTIFICATION OF WORK
SERVICE CALL

To be completed by the Contractor and saved in the Contractor's CMMS

Task ID Number: PA166

Date of Visit: 1-31-19 - 2-1-19

Contractor Personnel on Site:

1. Justin Zavacky

2. ~~Matthew~~

3. ~~Matthew~~

4. ~~Matthew~~

5. ~~Matthew~~

6. ~~Matthew~~

Service Call Number:

CSS# 16162 WO#

Description of Repairs

Replaced Bad motor for AHU5

HCP1 for Hot water coil.

Also Replaced AHUG Evap motor in Air handler and installed new fuses.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Justin Zavacky Date: 1-31-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the and government representative signature does not constitute acceptance of any work performed by the contractor. It only acknowledges that the contractor was on site during the identified timeline.

Print Name/Rank: SAC Subuktig Date: 1-31-19

Signed: 

E-Mail:

Michele Gray

From: Justin Zavacky
Sent: Sunday, February 03, 2019 10:34 PM
To: Michele Gray
Subject: Pa166



