

Michele Gray

From: 99R4 Service <99R4.Service@cmimgmt.com>
Sent: Wednesday, January 23, 2019 2:34 PM
To: Michele Gray
Cc: Joe Bayne; Bernie Koblinsky
Subject: Routine CM Call WO 7474, CSS 16927. PA053-02

f4053-

191604T

Michele,

CM WO 7475 has gone to CNC status and now combined with CM WO 7474...

WO 7474 CSS 16927-PA053-WO 7474 and 7475 Asset 4613 Unit Heater, Gas Fired Radiant, gas pressure regulator is too high. Repair gas regulator. Asset 4256 Unit Heater, Gas, Suspended, cracked heat exchanger/bad gas valve. Repair heat exchanger. Routine request.

Michele DuBois
Service Desk / 99th - Region 4
5285 Shawnee Road Suite #510
Alexandria, VA 22312
703-738-5307

