

Over and Above Repair Work – Order Number and Description of Work Completed

10377 - DUR INOPERABLE; FOUND INTERLOCK STICKING, DRIVE SPACER OUT OF ALIGNMENT, SAFETY KNOB BAD, AND MANUAL HOIST NOT WORKING
- UNJAMMED 3 ADJ. INTERLOCK SWITCH
- REALIGNED DRIVE SPACER
- REPLACED MISSING SET SCREW 3 ADJ. HOIST TO WORK
- ADJ. WHEELS, LUBED DUR, TOOK ZONE, AND TEST RAN

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: KENNETH K. KURSTRECK, JR Date: 2/1/19
Signed: Kenneth K. Kurstreck, Jr.

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Hannah L. Florian GS-09 Date: 20190201
Signed: Hannah Florian
E-Mail: hannah.l.florian.civ@mail.mil

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA 096

Date of Visit: 2/1/19

Contractor Personnel on Site:

1. <u>Ken Kuestick, Jr.</u>	4. _____
2. <u>Fisher Stewart</u>	5. _____
3. _____	6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____

Inspection, Testing, and Certification

1. _____
2. _____
3. _____
4. _____

Other Recurring Services

1. _____
2. _____
3. _____
4. _____

Service Calls – Service Call Number and Description

1. <u>10377 - Duct INOPERABLE</u>
2. _____
3. _____

PA096-01

Asset # 7721-Door,Ovhd-





