



SENTRY MECHANICAL
1724 Leechburg Road
Pittsburgh, PA 15235
(412) 795-3040
Fax (412) 795-3206
Job # 191107
Customer Name: CM I wishy for
Address: 10 scenic Dr Washington PA
Job Location:
Equipment Type: MAINT WOL
Model #: IY0454 A-161
Serial #: 1101012226
Equipment Location:
Area Served:
Equipment #:
Filter(s) (qty, size & type):
Belts(s) (qty, size & type):
Accessibility:
Evaluation:
Needs Ice machine not working properly
Ice probe & water sensor
00000 8660 Ice thickness probe \$68.25
00000 7052 water level probe \$43.17
AL from unit's Ref
Parts on same quote as motor for Exhausting
Photos Attached: Yes ☐ No ☐
Status: Incomplete ☐ Complete ☐
Priority 1-5: ☐ (5 Being High)
Service Tech: *Damon*
Reviewed By:
Date:
WHITE - Service Department
YELLOW - Job File
PINK - Technician

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

Facility/Building: PA096 Date of Visit: 2-5-19
Contractor Personnel on Site:
1. *Darren Young*
2.
3.
4.
Work Performed:
Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)
1. WO#
Service Calls - Service Call Number and Description
1. CSS# 16682
2. CSS# 15129
3. CSS# 17181
4. CSS# 16958
Assum Bl H/L
Ice machine
Exhaust fan
Gas Problem

To be signed by the Contractor:
Print Name: *Darren Young*
Date: 2-5-19
Signed: *Darren Young*
To be signed by Facility Manager:
I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:
Print Name/Rank: *Hannah L. Florian* AS-09
Date: 20190205
Signed: *Hannah Florian*
Hannah.L.Florian.civ@mail.mil