

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA011 Date of Visit: 9/25/2020

Contractor Personnel on Site:

- | | |
|--------------------------|----------|
| 1. <u>Marshall Kohne</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. BOND MONTHLY WATER TREATMENT
2. W00 #12726 asset # 190918-243
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Marshall Kohne Date: 9/25/2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Chris Chipps Date: 9/25/2020

Signed: 

E-Mail: _____

Tidewater, INC
VA-011
1821 Industry St.
Culpeper VA 22701
(410) 540-8700

Recorded By: **Marshall Kohne**
(301) 721-2663
mkohne@bondwater.com

Culpeper Minutemen Mem USARC - HVAC Equipment

Test	Closed Loop			
Conductivity (as mmhos)	2910 5000 max			
pH	10.2 8 - 10.5			
Molybdate (ppm as Mo)	50 50 - 200			

Evaporative Condenser

Online 

New system is being installed next month.

Closed Loop

Online 

All readings indicate good levels of protection for closed system. System is idle.