

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV020-02 Date of Visit: Jun 6, 2023

Contractor Personnel on Site:

- | | |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 93003 WO# 13036

Description of Repairs

Boiler vent cap got blown off n a wind storm.
replaced with new universal cap.



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Jun 6, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Shane Yokum / GS civ Date: Jun 6, 2023

Signed: 

E-Mail: shane.j.yokum.civ@army.mil