

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV010 Date of Visit: Jul 28, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

### Service Call Number

CSS# 94315 WO# 13427

### Description of Repairs

Found pressure sensor unplugged. plugged sensor back into duct work and unit started blowing good air flow



## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Jul 28, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Lee Smith / Sgt Date: Jul 28, 2023

Signed: 

E-Mail: lee.m.smith63.mil@army.mil