

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV020 Date of Visit: Mar 1, 2024

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 97004 WO# 15212

### Description of Repairs

Replaced diaphram and other internal components of toilet flush valve. toilet is operating order again.



## CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Richard A. Barker Date: Mar 1, 2024

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Lahomma Fowler / ARA GS09 Date: Mar 1, 2024

Signed: 

E-Mail: lahomma.d.fowler.civ@army.mil