

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029 Date of Visit: Apr 24, 2024

Contractor Personnel on Site:

| | |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 97249 WO# 15391

Description of Repairs

Found radiant heating coil had sprung a leak. Removed and made repair to rusty plug. tested that repair was good and reinstalled coil.



CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Apr 25, 2024

Signed: Richard A. Barker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: JenniferBailie / AFOS Date: Apr 25, 2024

Signed: Jennifer W. Bailie

E-Mail: jennifer.a.bailie.ctr@army.mil