

69405- [redacted]

28

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070

Date of Visit: 12-17-24

Contractor Personnel on Site:

1. MIKE' DEASON
2. JAKE TESCH
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

Service Call Number

98895

CSS# 08707

WO# 16644 16623

Description of Repairs

REPLACE M.U.A. TEMPERATURE SENSOR  
IN MOTOR POOL BUILDING MEZZANINE.  
CHECK OPERATION IN MANUAL AND  
FROM COMPUTER CONTROLS.

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Mike' Deason Date: 12-17-24

Signed: [Signature]


To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 12-19-2024

Signed: [Signature]

E-Mail: john.f.granata.ctr@army.mil



# POSTLER & JAECKLE

PLUMBING · HEATING · AIR CONDITIONING  
REFRIGERATION · SHEET METAL

24 HR EMERGENCY		1-800-724-4252	
NEW YORK OFFICES			
ROCHESTER	MAIN	585-546-7450	
	SERVICE	585-423-6214	
ALBANY	SERVICE	518-459-0910	
BINGHAMTON	SERVICE	607-757-0100	
SOUTHERN TIER	SERVICE	607-739-8303	
SYRACUSE	SERVICE	315-455-5587	
NEW JERSEY & PENNSYLVANIA		SERVICE	570-883-9563

Date	12/23/2024
Job No.	69405
Cost Code	000000028
Work Order No.	223020598
Ticket No.	20241105104443
Customer P.O.	16622

Customer US ARMY WEBSTER RESERVE CENTER (86804)

Address 515 RIDGE ROAD (NY070), WEBSTER NY 14580

Contact JOHN GRANATA (944-9099)

Description \*Q MUA TEMPERATURE SENSOR REPLACEMENT PER QUOTE CSS98895 ~NEED C.O.W FORM SIGNED(NEAR MOTOR POOL  
CATE/DAVE MOVINKIN)

## EQUIPMENT

Manufacturer	Model	Serial No.	Location	No.	Desc.	Parts Spec.
N/A	N/A	N/A				

## WORK PERFORMED

### Date Description

12/17/2024 Titan make up air unit. Shut down and remove discharge air sensor. Replace with new sensor. Turn unit back on and call tech support. Go over all operations. Change backup settings in controller. Cannot turn unit on in auto. Signal is not sent from Johnson controls. Wait until John is back to change settings in his computer. Unit is working properly.

## MATERIAL

Category	PO No.	Description
PO	069405-002800	Sensor, 1ea
Consumable		Wire nuts, electrical tape,

## LABOR

Date	Technician Name	Tech Id	ST	OT	DT	Shift	Remark
12/17/2024	Michael Deaton	01553		4.00			
		Total		4.00			

## TOOL RENTAL

Tool Description	Week Ending	M	T	W	T	F	S	S

## SUBCONTRACTOR

## RECOMMENDATION

Job Status	JOB STATUS COMPLETE	
Accepted By		
Tel		Signature
Email	julie.pape@tideh20.net;	
Comments		
Note: tools and materials may not reflect those listed on the final invoice.		Date

# POSTLER & JAECKLE

PLUMBING · HEATING · AIR CONDITIONING  
REFRIGERATION · SHEET METAL

24 HR EMERGENCY		1-800-724-4252	
NEW YORK OFFICES			
ROCHESTER	MAIN	585-546-7450	
	SERVICE	585-423-6214	
ALBANY	SERVICE	518-459-0910	
BINGHAMTON	SERVICE	607-757-0100	
SOUTHERN TIER	SERVICE	607-739-8303	
SYRACUSE	SERVICE	315-455-5587	
NEW JERSEY & PENNSYLVANIA	SERVICE	570-883-9563	

Date 12/23/2024  
 Job No. 69405  
 Cost Code 000000028  
 Work Order No. 223020598  
 Ticket No. 20241217082028  
 Customer P.O. 16622

Customer US ARMY WEBSTER RESERVE CENTER (86804)

Address 515 RIDGE ROAD (NY070), WEBSTER NY 14580

Contact JOHN GRANATA (944-9099)

Description \*Q MUA TEMPERATURE SENSOR REPLACEMENT PER QUOTE CSS98895 ~NEED C.O.W FORM SIGNED(NEAR MOTOR POOL  
 DATE DAVE MOVININ

## EQUIPMENT

Manufacturer	Model	Serial No.	Location	No.	Desc.	Parts Spec.
N/A	N/A	N/A				

## WORK PERFORMED

### Date Description

12/17/2024 Replacement of temp sensor and verification of operations. Spoke with John about controls and looked into adjusting set points unit was being held out by controls but works satisfactory and heats. Adjusted set points with John site contact and verified controls company had to come adjust due to limited access

## MATERIAL

Category	PO No.	Description

## LABOR

Date	Technician Name	Tech Id	ST	OT	DT	Shift	Remark
12/17/2024	Jake Tesch	05895	4.00				
		Total	4.00				

## TOOL RENTAL

Tool Description	Week Ending	M	T	W	T	F	S	S

## SUBCONTRACTOR

## RECOMMENDATION

Job Status	JOB STATUS COMPLETE	
Accepted By		
Tel		Signature
Email	julie.pape@tideh20.net;	
Comments		
Note: tools and materials may not reflect those listed on the final invoice.		Date