

CERTIFICATION OF WORK
SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FAC ID/Building USARC Clarksburgh Date of Visit 12-3 → 12-6

Contractor Personnel on Site

1. Keith Pearson

2. Wyatt Rose

3. _____

Service Call Number

CSS# 2992447 WO# 17684

Description of Repairs

installed All new pipe, wire, handend boards, and
peripheral devices. wired, programmed, & tested
with Fort McCoy.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Keith Pearson Date: 12-6-25

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Hepler, Christa SFC Date: 12-6-25

Signed: [Signature]

E-Mail: Christa.K.hepler.mil@army.mil



USARC Security Control Center

Alarm Loop Sheet for DSC Alarm Systems



Account Nr & Fac ID: 8110 WV 010	Location: Clarksburgh/ Bridgeport WV
DSC Panel Version: HS2032 V1.50	Panel Phone/Cell #: see picture
Panel's Dial Sequence: (EX 1-Nr or 9-1-Nr)	Number of Partitions:
Number of Microphones: 1	Number of Keypads: 1
MAC Address: 00034F65C090	IP Address:
IP Port Nr: 2	Switch Serial Nr: FDO1719Z1XN
Type(s) of Protected Area(s): Arms Vault	Communicator SIM #: see picture

Partition	Microphone	Alarm Point	Description	END OF LINE	
				Double	Single
		1	Vault Door		X
		2	Vault Door Tamper		X
		3	360 Motion 1		X
		4	360 Motion 1 Tamper		X
		5	360 Motion 2		X
		6	360 Motion 2 Tamper		X
		7	360 Motion 3		X
		8	360 Motion 3 Tamper		X
		9	Seismic 1		X
		10	Seismic 1 Tamper		X
		11	Seismic 2		X
		12	Seismic 2 Tamper		X
		13	Durress Button		X
		14	Siren Tamper		X
		15	Aux Power Supply AC fail		X
		16	Cabinet Tamper		X
		17	Aux Power Supply DC fail		X
		18			
		19			
		20			
		21			
		22			
		23			
		24			
		25			
		26			
		27			
		28			
		29			
		30			
		31			
		32			

Tech Name:	Tech Cell:
------------	------------

USARC Security Control Center Contact Information: PHONE 888-293-7353