

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029 BLDG2 Date of Visit: 3/31/25

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 3031003 WO# 18447

Description of Repairs

I found the breaker in the off position. I turned the breaker back on and found loose wires in the hydrostat I tightened up.

The wires and adjusted the thermostat on the unit.

And put the unit in the auto position and tested for proper operation

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 3/31/25

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer A Bailie/CTR Date: 04/30/2025

Signed: Jennifer A Bailie

E-Mail: jennifer.a.bailie.ctr@army.mil

