

USARC GRAFTON

COW + Photos

Brewer WO 106245

CERTIFICATION OF WORK
SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV014

Date of Visit: 5/21/25

Contractor Personnel on Site:

- | | |
|----------------------------|----------|
| 1. <u>Michael Moore</u> | 4. _____ |
| 2. <u>Jamie Dillsworth</u> | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

FEMS# 3114161

WO# 18512 18530

Description of Repairs

Replaced the Batteries in the fire panel and both nac power supplies. Also change the heat detector in the fuel room and the notification module. Fire panel is back to system normal now.
Brewer WO number 105315, QA025

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Michael Moore Date: 5/21/25

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Lahamma Fowler ARN, GSA Date: 20250521

Signed: Lahamma

E-Mail: lahamma.d.fowler.civ@army.mil





