

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV006 Date of Visit: 7-9-2024

Contractor Personnel on Site:

1. _____ 2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. July Pm

Service Calls – Service Call Number and Description

1. CSS#_____
2. CSS#_____
3. CSS#_____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brian Mcderment Date: 7-9-2024

Signed: Brian Mcderment

To be signed by Facility Manager:

By signing the Certification of Work, I certify that the above-named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed.
This is NOT a Certification that the Work was performed correctly – The COW simply verifies that that someone representing the Contractor was onsite and accomplished something

Print Name/Rank: Cpl Matthew Julian Date: 7-9-2024

Signed: Matthew Julian

E-Mail: Matthew.julian@usmc.mil



This T-stat has been damaged and will not move from 62 degrees and will need to be replaced. Asset 4043 Room 229 in the training bldg.



Found this ptac (Asset 4046) Room 202 in the training bldg. lock out on high pressure ,after investigating, found a piece of foam tape wedged in between the condenser and the fan schrow not allowing the fan to turn ,removed foam tape and verified operation ,p tac is running well now.