

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY052 BLDG2 Date of Visit: 12/14/23

Contractor Personnel on Site:

- |                         |          |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 4. _____ |
| 2. _____                | 5. _____ |
| 3. _____                | 6. _____ |

**Service Call Number**

CSS# 94586 WO# 13632


**Description of Repairs**

I removed the old tube heaters, venting and wiring that were  
not functioning properly then i installed 2 new tube heaters  
reconnected the vents along with relays to interreact with the  
BAC SYSTEM And tested for proper operation

**CERTIFICATION OF WORK**

To be signed by the Contractor:


Print Name: Patrick Brown Date: 12/14/23

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Travis McClellan, SSG Date: 12/14/23

Signed: 

E-Mail: \_\_\_\_\_

