

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY052 BLDG1 Date of Visit: 9/19/23

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 94697 WO# 13667

**Description of Repairs**

I tested 2 RPZ'S ONE 3/4 INCH AND ONE 2  
INCH , THE 2 INCH PASSED THE 3/4INCH  
FAILED

---

---

---

---

---


---

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 9/19/23

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 9/19/23

Signed: 

E-Mail: john.f.granata.cfr@army.mil



