

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029-02 Date of Visit: Apr 12, 2023

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 91851 WO# 12056

**Description of Repairs**

original W/O was for control boards being bad in 2 boilers, upon investigating found real problem was bad low water cut offs. replace cut offs and boilers are operating as they should be.

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Apr 12, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: David Ugarte / SFC Date: Apr 12, 2023

Signed: 

E-Mail: david.ugarte.mil@army.mil