

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV020-02 Date of Visit: Mar 23, 2023

Contractor Personnel on Site:

- |                        |          |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____               | 5. _____ |
| 3. _____               | 6. _____ |

**Service Call Number**

CSS# 92154 WO# 1210

**Description of Repairs**



Brewer was on site and everything on their end checks out ok. Upon investigating i found the exhaust fan damper not opeing properly and the boiler heat exchanger was blocked off with rust not allowing it to properly vent the flue gases. got exhaust vent unstuck and cleaned top of heat exchanger

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Mar 23, 2023

Signed: Richard A. Barker

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Shane Yokum / GS/civ Date: Mar 23, 2023

Signed: Shane Yokum

E-Mail: shane.j.yokum.civ@army.mil