

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD 019

Date of Visit: 7/7/2022

Contractor Personnel on Site:

1. B. Davis
2. _____
3. _____

4. _____
5. _____
6. _____

Service Call Number

CSS# 1376 WO# 18337

Description of Repairs

Chiller error codes - reset relay board on
System 2 running great

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brian Davis Date: 7/7/2022

Signed: B. Davis

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: ASON GAVIN AFOS Date: 7/7/22

Signed: Jason S

E-Mail: _____

ium™ Screw

SYS 1 OIL= 217 PSIG
SP= 66 DP= 236 PSIG

Entry

1	2	3
4	5	6
7	8	9

ENTER

CANCEL

↑

hium™ Screen

SYS 2 OIL = 151 PSIG
SP = 71 DP = 193 PSIG

Entry

1

2

3

4

5

6

ENTER

CANCEL

onium™ Screw

SYS 1 COMP RUNNING
SYS 2 COMP RUNNING

Entry

1

2

3

4

5

6

7

8

9

ENTER

CANCEL



