

## Additional Funding Request

Submitted: 7/12/22

<b>VA006</b>	<b>CSS 1410 WO 18347</b>								
Description of Repairs	Labor and Materials to repair issues found on the spray foam roof system: These issues include cracks and blisters that will need to be 3-coursed with fabric and coating. And will clean and remove debris from the gutters								
Original SC Investigative Diagnosis	\$0								
Diagnosis: Initial Work Order	Vegetation is in gutters causing blockage and needs to be removed.  The roof has been identified with severe damage causing leaks into the facility, Need temporary patch								
Explanation of Additional Costs for Repairs	N/A								
Additional Material Cost to Perform Repairs	<p><b>Materials Cost: \$0</b></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; padding: 2px;"><b>ITEM</b></th> <th style="text-align: left; padding: 2px;"><b>QUANTITY</b></th> <th style="text-align: left; padding: 2px;"><b>UNIT PRICE</b></th> <th style="text-align: left; padding: 2px;"><b>TOTAL</b></th> </tr> </thead> <tbody> <tr> <td style="text-align: left; padding: 2px;"><b>Materials (see attached for details)</b></td> <td style="text-align: left; padding: 2px;"><b>1</b></td> <td style="text-align: left; padding: 2px;"><b>\$0</b></td> <td style="text-align: left; padding: 2px;"><b>\$0</b></td> </tr> </tbody> </table>	<b>ITEM</b>	<b>QUANTITY</b>	<b>UNIT PRICE</b>	<b>TOTAL</b>	<b>Materials (see attached for details)</b>	<b>1</b>	<b>\$0</b>	<b>\$0</b>
<b>ITEM</b>	<b>QUANTITY</b>	<b>UNIT PRICE</b>	<b>TOTAL</b>						
<b>Materials (see attached for details)</b>	<b>1</b>	<b>\$0</b>	<b>\$0</b>						
Additional Labor Cost to Perform Repairs	<p><b>Whitley Labor: \$2,136.00</b>  <b>29.47 hrs/ \$72.50/hr (This is an average of Forman and helper rate)</b></p>								
<b>Total Cost of Repair</b>	<b>\$2,136.00</b>								

Hi Shara,

I was asked to put together a quote for the work that we did yesterday in addition to pricing for the additional work that needs to be done at 1634 Cherry St in Charlottesville.

The repairs yesterday totaled approx. \$1,402.00. There are about 3 additional hours of work to be done including gutters that need to be cleaned. That would cost an additional \$734.00.

Please let us know how you would like to proceed. See below link for photo:

# Whitley/Service

## Roofing & Sheet Metal Company of Charlottesville

P.O. Box 525  
Charlottesville, Virginia 22902  
(434) 984-0550  
Fax (434) 984-0549

### Contractors For:

Roofing  
Industrial Sheeting  
Sheet Metal Fabrication & Erection

VA. Contractor's Registration #2705157565-A

July 11, 2022

Shara Fortier  
Tidewater, Inc

RE: Army Reserve- Charlottesville

#### Note:

- We do not relinquish lien rights
- AIA contract
- Standard Insurance Certificate only
- Mutually agreed upon schedule
- No broad or intermediate indemnification

#### DESCRIPTION OF WORK TO BE PERFORMED:

- We will repair issues found on the spray foam roof system:
  - These issues include cracks and blisters that will need to be 3-coursed with fabric and coating
- We will clean and remove debris from the gutters

#### TOTAL PRICE:

**Two Thousand One Hundred Thirty Six DOLLARS..... \$2,136.00**

#### Labor Rates:

- Foreman- \$80/hr
- Helper- \$65/hr

\* In the event the price of any materials, products, labor, or freight to be used in this work should increase 5% or greater from the price at which the material/product, labor, or freight was available to the contractor at the time of submission of this proposal, then the price quoted shall be increased to reflect the additional cost.

#### ACCEPTED:

Firm/Owner: \_\_\_\_\_

WHITLEY/SERVICE ROOFING & SHEET METAL COMPANY

By: \_\_\_\_\_

By: Brett Larson \_\_\_\_\_

Title: \_\_\_\_\_

Title: President \_\_\_\_\_

Date: \_\_\_\_\_

Date: July 11, 2022 \_\_\_\_\_

The terms and conditions set forth on the reverse side are a part of this proposal and contract. This Proposal is subject to revision or withdrawal by Whitley/Service until communication of acceptance and may be revised after communication of acceptance where an inadvertent error by Whitley/Service has occurred. This Proposal expires thirty (30) days after the date stated above, unless Whitley/Service Roofing & Sheet Metal Company expressly agrees to an extension in writing.

(See reverse side for terms and conditions)









