

Additional Funding Request

Submitted: **05/04/2022**

VA048-PTAC	CSS 151 WO 17320								
Description of Repairs	S&S proposes to remove and replace the condensate pump and add refrigerant to the system. Then, complete a system check to ensure everything is working properly.								
Original SC Investigative Diagnosis	\$500								
Diagnosis: Initial Work Order	PTAC near room 205A in the hall is making loud noise								
Explanation of Additional Costs for Repairs	N/A								
Additional Material Cost to Perform Repairs	<p>Materials: \$ 312.84</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; padding: 2px;">ITEM</th> <th style="text-align: left; padding: 2px;">QUANTITY</th> <th style="text-align: left; padding: 2px;">UNIT PRICE</th> <th style="text-align: left; padding: 2px;">TOTAL</th> </tr> </thead> <tbody> <tr> <td style="text-align: left; padding: 2px;">See attached detail</td><td style="text-align: left; padding: 2px;">1</td><td style="text-align: left; padding: 2px;">312.84</td><td style="text-align: left; padding: 2px;">312.84</td></tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	See attached detail	1	312.84	312.84
ITEM	QUANTITY	UNIT PRICE	TOTAL						
See attached detail	1	312.84	312.84						
Additional Labor Cost to Perform Repairs	<p>Labor: \$1600 16 hours each/ \$100= \$1600</p>								
Total Cost of Repair	\$2412.84								



S&S MECHANICAL

S&S Mechanical
4831 South Crain Highway
Upper Marlboro, MD 20772

Tel. 1 - (301) 574-1555
Fax. 1 - (301) 574-1558
www.sandsmidatlantic.com

CUSTOMER QUOTATION NO. 1014

Tidewater, Inc.
Tidewater, Inc
6625 Selnick Dr.
Suite A
Elkridge MD 21075

Quote Name: 17320
Quote No: 1014
Site: VA048
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 04/27/2022
Valid For: 30 Day(s)

WO#: 17320

CSS Ticket Number: 151

Problem: PTAC near room 205A in the hall is making loud noise.

POC Angela Williams Taylor 757-544-7039

S&S proposes to remove and replace the condensate pump and add refrigerant to the system. Then, complete a system check to ensure everything is working properly.

Service

Item	Quantity	Unit Price	Total
EC-1-DV 2.5 GPH Mini Condensate Removal Pump	1.00	\$150.34	\$150.34
5lbs R410A	1.00	\$112.50	\$112.50
Shipping	1.00	\$50.00	\$50.00
Diagnosis Fee	1	\$500.00	\$500.00
HVAC Labor Rate	16	\$100.00	\$1,600.00
		Sub-Total ex Tax	\$2,412.84
		Tax	\$0.00
		Total inc Tax	\$2,412.84

Labor	\$2,100.00
Materials	\$312.84
Sub-Total ex Tax	\$2,412.84
Tax	\$0.00
Total inc Tax	\$2,412.84


U



PATENT
PENDING

IP20

Made in Mexico
LITTLE GIANT
OKLAHOMA CITY, OK USA



553505

MODEL EC-1-DV
110-240V~ 50/60Hz
0.18A 1 PHASE
THERMALLY PROTECTED

DUTY CYCLE 50%

NON SUBMERSIBLE
CONDENSATE
INDOOR USE ONLY

15L14 23 02291W

8:42



supplyhouse.com



HELP



MENU



Search



SIGN IN



CART

Pros, Join Our **TRADEMASTER** Program! [APPLY FOR FREE >](#)

[← Mini-Split/Ductless Condensate Removal Pumps](#)

EC-1-DV 2.5 GPH Mini Condensate Removal Pump (110-240V)

SKU: 553507 Brand: Little Giant



(1)



\$125.28 each



ADD TO CART

● Backorder

Add to List

Get it Thu, Jun 2 – Thu, Jun 30

8:49



< All Inboxes

2 Messages



Refrigerant Quote

Good morning,

Could you send me a quote for 25lbs of R410A

Lindsay Ruby

S&S Mechanical

"Feeling Good About What We Do"

Phone: [301-574-1555](tel:301-574-1555)

Fax: [301-574-1558](tel:301-574-1558)

www.sandsmidatlantic.com

lindsay@sandsmidatlantic.com

See More



br12 Annapolis

8:25 AM

To: Lindsay Ruby >

\$468.75

From: Lindsay Ruby

[\[mailto:lindsay@sandsmidatlantic.com\]](mailto:lindsay@sandsmidatlantic.com)

Sent: Tuesday, May 03, 2022 8:07 AM

To: br12 Annapolis <br12>Annapolis@aireco.com>

