

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY030 Date of Visit: 6 Dec 18

Contractor Personnel on Site:

- |          |          |
|----------|----------|
| 1. _____ | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

**Service Call Number**

CSS# 15954 WO# 5966

**Description of Repairs**


Replaced pressure relief Valve on Boiler #2  
Removed condensate drain / trap And Flushed  
put BACK together, And let unit run.

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Joseph Smith Date: 6 Dec 18

Signed: 


To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: David L Becker SFC Date: 6 Dec 2018

Signed:  SFC

E-Mail: david.l.becker1.mil@mail.mil



MODEL RVW6

SIZE

1/4

1/4

1/4





