

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD 003 Date of Visit: 02-01-2019

Contractor Personnel on Site:

- | | |
|-----------------|----------|
| 1. <u>Jenny</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Calls – Service Call Number and Description

CSS 16337

- WD 6470 - CHANGED CND PRESSURE SWITCH FOR BOILER #1
- AND CLEANED IGNITOR AND FLAME SENSOR FOR
- BOILER #1. BOILER #2 NEEDS DRAFT INDUCER WORK

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: JAMES SPACKMAN Date: 02-01-2019

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Gilligan Reginald Date: 1 Feb '19

Signed: [Signature]

E-Mail: Reginald.P.Gilligan.mil@Dmail.mil



GAS PRESSURE SWITCH

UL LISTED
1754
HEATING/COOLING APPLIANCE SWITCH

ELECTRICAL RATING
3.0AFL/18.0ALR @120/240VAC

TEMPERATURE -40°F TO 140°F (-40°C TO 60°C)
FOR SUPPLY CONNECTIONS USE WIRE
SUITABLE FOR AT LEAST 75°C.
FOR MOUNTING TO HONEYWELL V5097
VALVE ONLY.

Honeywell
MINNEAPOLIS, MN 55422
MADE IN JAPAN

81408276-003-04

08160