

Additional Funding Request

Submitted: 07/25/2022

VA049	CSS 1634 WO 18467								
Description of Repairs	Labor and materials to return to site to remove and replace the high temperature switch. Start, test and ensure proper unit operations.								
Original SC Investigative Diagnosis	\$0								
Diagnosis: Initial Work Order	Boiler #4 needs a high limit safety switch								
Explanation of Additional Costs for Repairs	N/A								
Additional Material Cost to Perform Repairs	<p>Materials: \$ 181.14</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; padding: 2px;">ITEM</th><th style="text-align: left; padding: 2px;">QUANTITY</th><th style="text-align: left; padding: 2px;">UNIT PRICE</th><th style="text-align: left; padding: 2px;">TOTAL</th></tr> </thead> <tbody> <tr> <td style="padding: 2px;">Materials (See attached detail)</td><td style="padding: 2px; text-align: center;">1</td><td style="padding: 2px; text-align: center;">181.14</td><td style="padding: 2px; text-align: center;">181.14</td></tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	Materials (See attached detail)	1	181.14	181.14
ITEM	QUANTITY	UNIT PRICE	TOTAL						
Materials (See attached detail)	1	181.14	181.14						
Additional Labor Cost to Perform Repairs	<p>Labor: \$600</p> <p>Moore's Labor \$120/ hr x 5</p>								
Total Cost of Repair	\$781.14								



P.O. Box 119 • Altavista, VA 24517 • 24 Hour Service: 800.789.7199 • Fax: 888.722.2712 • MooresElectric.com

Proposal

July 25, 2022

Quotes are valid for 14 days.

USARC - VA049
6700 STRATHMORE ROAD
NORTH CHESTERFIELD, VA 23237
Email adam.colopy@tideh2o.net & Mary.Lowery@tideh2o.net

Contact Name Mary Lowery & Adam Colopy
Telephone 0.00
Cell Phone 614-623-9569
WO # 0.00

DESCRIPTION OF EQUIPMENT:

Make: Alpine
Model: Alp399F-1I07
Serial: 65174827

DESCRIPTION OF PROBLEM:

After installing a new gas valve. Technician started the boiler found the high temperature limit was indicating 'good', but it was not allowing the signal to pass through. Will need to replace the limit and recheck boiler operations.

DESCRIPTION OF REPAIRS:

Technician will return to site to remove and replace the high temperature switch. Start, test and ensure proper unit operations.

MATERIAL, EQUIP OR PARTS

	Quantity	Sell price
High Temp Switch	1.00	\$ 106.14
Fuel Surcharge	1.00	\$ 20.00
Truck Fee	1.00	\$ 55.00
Material Total	\$	181.14

LABOR ITEMIZED

		Labor
Labor - One Man	5	\$ 120.00 \$ 600.00
Labor - Second Man	0	\$ 120.00 \$ -
Labor Total		\$ 600.00

Thank you for your business. If you have any questions or concerns, please feel free to contact us via telephone or quotes@mooreselectric.com

Materials	\$	181.14
Labor	\$	600.00
TOTAL	\$	781.14

Robert Lowery, Changeout Estimator 434-309-2591
James Davis, Estimator 434-309-2568
Marvin Slaughter, Estimator 434-369-3514
Jared Underwood, Estimator 434-306-2446

Approved by: _____

In consideration of Moore's Electrical & Mechanical extending credit to the above applicant, the undersigned hereby guarantees unconditionally and irrevocably. The compliance of all terms of the application and agreement, including the payment of any sums within the net terms agreed upon between the customer and Moore's, plus any additional costs such as a 1.5% monthly interest charge starting once an invoice becomes 30 days past due, service charges, legal fees and any means taken in order to collect debt. If it is deemed necessary to litigate, it is agreed that the County or District Court of Campbell County, Virginia shall be the venue of any suit. This guarantee shall remain in full force unless and until notice in writing is sent certified mail and received by Moore's Electrical & Mechanical. Said notice cannot be within 14 days of this signed agreement.

5 PSIG Out
Outlet Pressure
ONE R.E. MICHEL COMPANY LLC
ONE R.E. MICHEL DRIVE
GLEN BURNIE, MD 21060
PHONE #: (804) 672-0202

REM LOCATION# - 124
7/22/22 CU# 430920 OR# 401068 N
CUST PH # 434-369-4374 FAX # 434-369-2230

FAX #: (804) 672-0236

7/22/22 NET 10TH PROX SMILLER

MOORE'S ELECTRIC
PO BOX 119
ALTAVISTA, VA 24517-0119

MOORE'S ELECTRIC
PO BOX 119
ALTAVISTA, VA 24517-0119

WHSE 124 16:07 PAGE 1
HANDLING :
SHIP VIA : CPU CUSTOMER PICK-UP
CUSTOMER PO: MS296353
SALES ID : 951890 STEVEN D. WRAY

FRGHT BILL#:

BIN #	ORD QTY	SHP QTY	ITEM NUMBER	CASE	DESCRIPTION	QTY	AVL	QTY	O/H	W	PRICE
1	0	0	2W7816	1	107121-01 HIGH LIMIST TEMP SWI	0		0			88.45
				EA	ALPINE 107121-01 HIGH LIMIT SE						

ALPINE M) ALP399F-1L07 S) 65174827
ORDERED BY PETER