

## **CERTIFICATION OF WORK SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE002 B-1 Date of Visit: 1/16/19

#### Contractor Personnel on Site:

1. John Brown
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

## Service Call Number

CSS# 16388 WO# 6841

## Description of Repairs

Remove and replace 3 thermostats and test accuracy.

## CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Johnny W. Brown Date: 1/16/19

Signed: John W. Doe

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: GS9 Hector Castellanos Date: 1/16/19

Signed: 

E-Mail: \_\_\_\_\_

AR 420-1 mandates the  
following thermostat settings:  
Heating = 68°F & Cooling = 76°F

