

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE001 B-1

Date of Visit: 12/4/18

Contractor Personnel on Site:

1. John Brown
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

### Service Call Number

CSS# 16570 WO# 6831

### Description of Repairs

Heating system replace broken Actuator motor and turn on valve that was turned off in the ceiling

---

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W. Brown Date: 12/4/18

Signed: Johnny W. Brown

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Sánchez González, Jessica E. Date: 4 Dec. 18

Signed: Jessica E. Sanchez  
E-Mail:

**t.a.c**   
AG13A020

**Erie**



**AG13A020**

1X



Erie  
Pop Top Actuator

ASSEMBLED IN USA  
AN-1814

US Patents 6,073,907, Des. 400,967;  
Foreign Patents Pending


2 Position Normally Closed  
24V 50/60Hz 6.5WATTS CLASS 2

N1831

7

11426 60183

1



**Schneider**  
Electric

