

Additional Funding Request

MD024	CSS# 16597 WO# 7158 Asset# 2167											
Description of Repairs	Labor and materials to replace sensing edge on overhead door.											
Diagnosis: Initial Work Order	Roll up door in building 1005 not working properly. Doors opens but will not close when close button is pushed. Door begins to close then reopens shortly after starting to close.											
Diagnostic Fee	\$0											
Additional Labor Cost to Perform Repairs	<p>\$ 320</p> <p>TW Labor \$80/hr x 4</p>											
Additional Material Cost to Perform Repairs	<p>\$614.79</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">12' Miller Edge 4 Wire Monitored Safety Edge</td> <td style="width: 15%;">1</td> <td style="width: 15%;">\$583.20</td> <td style="width: 15%;">\$583.20</td> </tr> <tr> <td>Sales Tax</td> <td></td> <td></td> <td>\$31.59</td> </tr> </table>				12' Miller Edge 4 Wire Monitored Safety Edge	1	\$583.20	\$583.20	Sales Tax			\$31.59
12' Miller Edge 4 Wire Monitored Safety Edge	1	\$583.20	\$583.20									
Sales Tax			\$31.59									
Total Cost of Repair	\$ 934.79											



WORK ESTIMATE

CSS #:

16597

Work Order #:

7158

Emergency

Urgent

Routine

X

Company Name:	Tidewater, Inc.	Facility ID:	MD024
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	Building 1005
E-Mail Address:	adam.colopy@tideh2o.net		
Assigned Technician(s):	John Brown		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and materials to replace sensing edge on overhead door.

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Labor			4	\$320.00
12' Miller Edge 4 Wire Monitored Safety Edge	1	\$583.20		\$583.20
Sales Tax				\$31.59
SUB-TOTAL COSTS:		Materials Total	\$614.79	Labor \$320.00
		TOTAL		\$934.79



3501 Century Ave. • Baltimore, MD 21227 • Phone: 410-636-6300 • Fax: 410-636-4308

Date: 1/11/19

Quote Is Valid For 60 Days

Attention: John Brown

Fax Back To: 410-636-4308

Tidewater
6625 SELNICK DR. Suite A
Elkridge MD

Phone: 410-562-1511
Email: john.brown@tideH2o.net

P R O P O S A L

The Overhead Door Company Of Baltimore, Inc. is pleased to propose the following:

Replacement Safety Edge Supply Only

Materials:

Qty (1) 20'0" Miller Edge 4 Wire Monitored Safety Edge With Mounting Channel.....\$810.00

Qty (1) 12'0" Miller Edge 4 Wire Monitored Safety Edge With Mounting Channel.....\$486.00

Total Cost: \$1,296.00 + Tax If Applicable
(For Customer Pick Up)

Should You Have Any Questions Concerning This Proposal, Please Do Not Hesitate To Contact Me Directly.

Thank you,

John Gunnet

John Gunnet – Commercial Sales/Service
Overhead Door Co. Of Baltimore, Inc.
Phone: 443-820-7993 / Fax: 410-636-4308
Email: jgunnet@ohdbalt.com

Upon Acceptance Of This Proposal, Please Sign,
Date And Return One Copy To Our Office.

X _____ Date: _____ PO#: _____
(Customer Signature) (If Applicable)



We Also Specialize In The Installation Of
Hollow Metal / Wood Doors & Hardware
From Several High Quality Manufacturers.

This quotation/proposal from Overhead Door Company of Baltimore is for the sole use of the intended recipient or recipients and may contain confidential and privileged information. Any unauthorized review, use, disclosure, distribution, or other dissemination of this quotation/proposal and/or the information contained therein is strictly prohibited. If you are not the intended recipient of this quotation/proposal, please contact the sender and destroy all copies.

