

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY126 Date of Visit: 12/17/2018

Contractor Personnel on Site:

- | | |
|-----------------------|----------|
| 1. <u>Sean O'Dell</u> | 4. _____ |
| 2. <u>Sean Baker</u> | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 16696 WO# 6844

Description of Repairs

Boiler drain behind Vulcan stoves leaking down the wall and leaking down onto electrical outlet
Climbed into ceiling to shut water supply off removed old boiler drain and gfcı outlet. Installed
new boiler drain and new gfcı outlet. Turned water back on and tested outlet and boiler drain to ensure
that nothing is leaking and that the outlet and oven are working properly. Job is complete

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Sean O'Dell/Sean Baker Date: 12/17/2018

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____

Signed: _____

E-Mail: _____



TKP1 #18,20

TKP1

18,20

TKP1





SEE INSTRUCTIONS

RESET

TEST



GUN GRAY MFG. CO. INC.



