

CERTIFICATION OF WORK
SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA209

Date of Visit: 12/19/18

Contractor Personnel on Site:

1. Eric Busa

4. _____

2. _____

5. _____

3. _____

6. _____

Service Call Number

CSS# 16709

WO#

6857

Description of Repairs

The PTAC Unit in Room 141 was blowing cold air with a call for heating when I first arrived. This unit is equipt with a manual reset switch that was tripped. I reset the switch and it is now operating as it should.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Eric Busa


Date: 12/19/18

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: RICHARD ELLIOTT, GS-09 Date: 2018/12/19

Signed: 

E-Mail: RICHARD.E.ELLIOTT 49, CIV@MAIL.MIL



Honeywell

Inside 74° Set To 74°



Fan



Auto On

System



Cool Off Heat