

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD 19 Date of Visit: 2.7.2019

Contractor Personnel on Site:

- | | |
|-----------------------|----------|
| 1. <u>Brian Davis</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Calls – Service Call Number and Description

1. Boiler #1 PHW750 NB# 107020 installed new "Flame" switch
2. Boiler #2 PHW750 NB# 107145 installed pressure relief valve
3. Boiler #3 PHW750 NB# 107140 install gas shutoff valve, "Flame" switch

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brian Davis Date: 2.7.2019

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC W. L. Disgen Date: 2/7/19

Signed: [Signature]

E-Mail: _____

Gas Orifice
Do Not Open Unless
There is NO Pressure
in This Bomb



