

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA 49

Date of Visit: 7/20/22

Contractor Personnel on Site:

1. Josh Castle
2. Ease Wane
3. _____

4. _____
5. _____
6. _____

Service Call Number

CSS# _____ WO# 18472

Description of Repairs

MASS Repairs to ATR, began replacing beams
on ATR. ATR is incomplete, will return 7/21.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Ease Wane Date: 7/20/22

Signed: Ease Wane

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LTC Jeremiah C. Hood Date: 20 JUL 22

Signed: LTC Hood

E-Mail: jeremiah.c.hood.mil@army.mil

CERTIFICATION OF WORK
SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA 49

Date of Visit: 7/14/22

Contractor Personnel on Site:

1. Abasirah Hillman
2. Eric Ware
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# _____ WO# 18472

Description of Repairs

CH1000 offsite /locked out due to plugged
Condenser coils & failed suction lines & transducers
Cleaned coils while on site, restored chiller 145.
#1 AMU has heat damage. Parts ordered.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Eric Ware Date: 7/14/22

Signed: Eric Ware

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LTC Jeremiah C. Hood Date: 20 JUL 22

Signed: LTC Hood

E-Mail: jeremiah.c.hood.mil@army.mil