

Additional Funding Request

DE007	CSS# 16824 WO# 6886 Asset# 1782											
Description of Repairs	Labor and materials to replace control board on asset 1782 OMS Heater. We replaced the blower motor, however, that revealed a faulty control board that requires replacement.											
Diagnosis: Initial Work Order	The heat in the offices of the OMS building doesn't seem to be working. POC is MSG Cox at 910-598-5435 or Mr. Corti at 302-266-5936											
Diagnostic Fee	\$0											
Additional Labor Cost to Perform Repairs	<p>\$ 320</p> <p>TW Labor \$80/hr x 4</p>											
Additional Material Cost to Perform Repairs	<p>\$253.00</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Board Control Kit L44-832 S1-33102977000</td> <td style="width: 10%;">1</td> <td style="width: 20%;">\$240.00</td> <td style="width: 20%;">\$240.00</td> </tr> <tr> <td>Sales Tax</td> <td></td> <td></td> <td>\$13.00</td> </tr> </table>				Board Control Kit L44-832 S1-33102977000	1	\$240.00	\$240.00	Sales Tax			\$13.00
Board Control Kit L44-832 S1-33102977000	1	\$240.00	\$240.00									
Sales Tax			\$13.00									
Total Cost of Repair	\$ 573.00											



WORK ESTIMATE

CSS #: Work Order #:
Emergency Urgent Routine

Company Name:	Tidewater, Inc.	Facility ID:	DE007
Contractor POC:	Adam Colopy		
Telephone No:	740-819-6207	Building/Location; (e.g., Classroom/Room #)	OMS
E-Mail Address:	adam.colopy@tideh2o.net		
Assigned Technician(s):	John Brown		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and materials to replace control board on asset 1782 OMS Heater.

We replaced the blower motor, however, that revealed a faulty control board that requires replacement.

LABOR/MATERIAL		MATERIAL/ SUB UNIT DOLLAR AMOUNT	LBR/HR \$80	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Labor			4	\$320.00
Board Control Kit L44-832 S1-33102977000	1	\$240.00		\$240.00
Sales Tax				\$13.00
SUB-TOTAL COSTS:		Materials Total	\$253.00	Labor \$320.00
		TOTAL		\$573.00



JOHNSTONE SUPPLY #408
19 E. COMMONS BLVD SUITE #3
NEW CASTLE, DE 19720
302-323-9600
Fax 302-323-1274



Quotation

EXPIRATION DATE	QUOTE NUMBER
02/21/2019	408-100145609
JOHNSTONE SUPPLY #408 19 E. COMMONS BLVD SUITE #3 NEW CASTLE, DE 19720 302-323-9600 Fax 302-323-1274	PAGE NO.
	1 of 1

QUOTE TO:

SHIP TO:

Tidewater Inc.
6625 Selnick Drive
ELKRIDGE, MD 21075

Tidewater Inc.
6625 Selnick Drive
ELKRIDGE, MD 21075

CUSTOMER NUMBER	CUSTOMER PO NUMBER	JOB NAME / RELEASE NUMBER		SALESPERSON
4087				House Account
WRITER	SHIP VIA	TERMS	SHIP DATE	FREIGHT ALLOWED
Julio Mangini		NET 30 DAYS	01/07/2019	No
ORDER QTY	DESCRIPTION	UNIT PRICE	EXT PRICE	
1ea	L44-832 S1-33102977000 BOARD CONTROL KIT	200.000/ea	200.00	
		Subtotal	200.00	
		S&H Charges	0.00	
		Amount Due	200.00	



