

Additional Funding Request

| | | | | | | | | | | | | |
|---|---|----------|----------|--|---|---|----------|----------|-----------|--|--|---------|
| DE001 | CSS# 16881 WO# 6877 Asset# 1687 | | | | | | | | | | | |
| Description of Repairs | Labor and materials to replace electric unit Heater. | | | | | | | | | | | |
| Diagnosis: Initial Work Order | Unit Heater is non operational and requires replacement. | | | | | | | | | | | |
| Diagnostic Fee | \$0 | | | | | | | | | | | |
| Additional Labor Cost to Perform Repairs | <p>\$ 400</p> <p>TW Labor \$80/hr x 5</p> | | | | | | | | | | | |
| Additional Material Cost to Perform Repairs | <p>\$964.94</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Electric Unit Heater - TPI HF2B5110CA1L</td> <td style="width: 10%; text-align: center;">1</td> <td style="width: 10%; text-align: center;">\$915.41</td> <td style="width: 10%; text-align: center;">\$915.41</td> </tr> <tr> <td>Sales Tax</td> <td></td> <td></td> <td style="text-align: center;">\$49.53</td> </tr> </table> | | | | Electric Unit Heater - TPI HF2B5110CA1L | 1 | \$915.41 | \$915.41 | Sales Tax | | | \$49.53 |
| Electric Unit Heater - TPI HF2B5110CA1L | 1 | \$915.41 | \$915.41 | | | | | | | | | |
| Sales Tax | | | \$49.53 | | | | | | | | | |
| PM Credit | (\$250) | | | | | | | | | | | |
| Total Cost of Repair | \$ 1,114.94 | | | | | | | | | | | |



WORK ESTIMATE

CSS #:

16881

Work Order #:

6877

Emergency

Urgent

Routine

| | | | |
|-------------------------|--|---|-------------|
| Company Name: | Tidewater, Inc. | Facility ID: | DE001 |
| Contractor POC: | Adam Colopy | | |
| Telephone No: | 740-819-6207 | Building/Location; (e.g., Classroom/Room #) | Boiler Room |
| E-Mail Address: | adam.colopy@tideh2o.net | | |
| Assigned Technician(s): | John Brown | | |

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

Labor and materials to replace unit heater in boiler room.

| LABOR/MATERIAL | | MATERIAL/ SUB UNIT DOLLAR AMOUNT | LBR/HR \$80 | LINE ITEM TOTAL DOLLAR AMOUNT |
|---|----------|---|-----------------|--|
| ITEM | QUANTITY | | | |
| Labor | | | 5 | \$400.00 |
| Electric Unit Heater - TPI HF2B5110CA1L | 1 | \$915.41 | | \$915.41 |
| Sales Tax | | | | \$49.53 |
| SUB-TOTAL COSTS: | | Materials Total | \$964.94 | Labor \$400.00 |
| | | TOTAL | | \$1,364.94 |



MAURICE ELECTRICAL-ANNAPOLIS
1981 MORELAND PARKWAY
BLDG 5
ANNAPOLIS, MD 21401-3459
410-573-5114
Fax 410-573-5260

QUOTE TO:

TIDEWATER INC
6625 SELNICK DR STE A
ELKRIDGE, MD 21075-6220



Quotation

| QUOTE DATE | QUOTE NUMBER | PAGE NO. |
|------------|--------------------|----------|
| 01/14/2019 | S112267485 | 1 of 1 |
| CUST PO#: | HF2B5110A1L HEATER | |
| JOB/REL#: | | |

SHIP TO:

TIDEWATER INC
6625 SELNICK DR STE A
ELKRIDGE, MD 21075-6220

| CUSTOMER NUMBER | CUSTOMER PHONE | ORDERED BY | SALESPERSON | |
|--|---|----------------------------|-----------------|----------------|
| 291492 | 410-540-8700 | JOHN BROWN | HOUSE ACCOUNT | |
| WRITER | SHIP VIA | TERMS | EXPIRATION DATE | FREIGHT EXEMPT |
| CHARLES MIKE STAPF 410-573-5114 | 4BD3BALTDOWNTO WN | MFG DISC 10TH, NET 15TH | 02/13/2019 | No |
| ORDER QTY | DESCRIPTION | UNIT PRICE | EXT PRICE | |
| 1ea | TPI HF2B5110CA1L 10KW 240V 1/3P/7.5KW 208V 1/3P UNIT HTR | 762.840/ea | 762.84 | |
| Prices listed on this quotation are subject to change without notice beyond expiration date, include only the equipment listed and do not include any sales tax unless noted otherwise. Expiration date does not apply to commodity pricing which may be subject to change after 24 hours. Special order items cannot be cancelled unless the manufacturer permits cancellation. | | Subtotal | 762.84 | |
| | | Shipping Chgs | 0.00 | |
| | | Amount Due | 762.84 | |

TPI CORPORATION
P.O. BOX 4973, CRS
JOHNSON CITY, TN 37602-4973
AIR HEATER
MODEL **HF2B5110CA1L**

U.L. LISTED

547G



| HEATER/RADIATEUR | | 60 HZ |
|------------------|------------------|------------------|
| VOLTS | 240 | 208 |
| KW | 10.0 | 7.50 |
| PHASE | 1/3 | 1/3 |
| AMPS | 42.2/24.6 | 36.7/21.4 |

| MOTOR / MOTEUR | |
|----------------|----------------|
| VOLTS: | 240/208 |

| CONTROL CIRCUIT | |
|-----------------|-----------|
| VOLTS: | 24 |

| MIN. CIRCUIT AMPACITY | |
|---------------------------|-------------|
| INTENSITE MIN. DU CIRCUIT | AMPS |

| MAX. OVERCURRENT DEVICE RATING | |
|---|-------------|
| TENSION DE SURVOLT, MAX. DE L' APPAREIL | AMPS |

60721-046

TASKMASTER

Building 1
Asset#1687 UH