

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY070 Date of Visit: 16 Jan 2019

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Arthur Temple</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 17102 WO# 7189

Description of Repairs


Removed ice, dried surfaces, applied sealant between panel and fascia, screwed self drilling
roofing screws every three inches and applied sealant to the end seams.

Cleaned all trash from area.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Arthur Temple Date: 16 Jan 2019

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata AFOS Date: 17 JAN 19

Signed: 

E-Mail: jfn.f.granata@tre.marl.mil



