

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 B-1 Date of Visit: 1/11/19

Contractor Personnel on Site:

1. John Brown
2. _____
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 17177 WO# 7265

Description of Repairs

I found the hot water circulating pumps running even though the computer was calling for them to run. I switch the controls to bypass and could get the pumps to run in manual control.

this is a continuing problem with the EMS system that needs to be upgraded and we are still waiting on approval for this process.

I'm referring to CSS 12250... So we will have to operate in bypass mode until controls are upgraded and maintained.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W. Brown Date: 1/11/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Danielle Barrett, SSA Date: 1/11/19

Signed: 

E-Mail: _____

